

**HIGH COURT OF MADHYA PRADESH: JABALPUR**

**// CLARIFICATION //**

No. Reg(IT)(SA)/2016/1127

Jabalpur, Dated:28.11.2016

**Subject:-** The matter relates to publish the clarification of the Pre-Bid meeting dated: 15<sup>th</sup> November, 2016 regarding “Expression of Interest” (EOI) for Design, Build, Operate and transfer of Data Center and IT Center at High Court of Madhya Pradesh, Jabalpur. with reference to the tender no. Reg(IT)(SA)/2016/1052, Dated:26.10.2016.

**Ref: -** Pre-Bid Meeting Dated: 15<sup>th</sup> November, 2016 at 11:30 A.M.

**Reply / clarification to the pre-bid query.**

S.No.	Clause / condition, Page no.	Query of the bidder	Reply / clarification to the query
1.	-	As per point no 7 VI bidder has to abide by the terms and condition of the High Court of M.P., Jabalpur. We request you to share the details of same for better understanding.	Please visit High Court of M.P., Jabalpur
2.	-	Annexure A Point No. 4 we request you to consider the Tier III Data Center or Tier IV standards.	Yes, Tier III data center or Tier IV standards are acceptable for “EOI” submission
3.	-	Kindly help to share the layout of the space to prepare the design.	The same shall be shared at the time of RFP.
4.	-	Annexure A point no. 2 against turnover, we request you to consider that the bidder must have an average turnover of Rs. 500 crore during last three financial years.	No change
5.	-	We request to add the following clause in pre-qualification “the bidder should have at least 3 uptime certified SME (Subject Matter expertise) on their payroll” on their payroll” for better	No change.

		capability of the bidder	
6.	-	Please clarify that the bidder has to obtain the tier and leed certification of the data center post build under the scope of work.	Yes required.
7.	-	Please confirm the uptime certification is required for design or not under the scope of work.	Yes required.
8.	“Annexure-A” Eligibility criteria, Page no. 11	<p>Should have constructed at least on Data Center in India or abroad with at least the following certifications:</p> <p>(A) Uptime Institute’s Tier IV standards for:</p> <ul style="list-style-type: none"> <li>• Tier certification of Design Documents</li> <li>• Tier certification of constructed facility</li> </ul> <p style="text-align: center;">Or</p> <p>(B) ANSI / TIA- 942 Rating 4 certification for:</p> <ul style="list-style-type: none"> <li>• ANSI/TIA-942 Design certification</li> <li>• ANSI/Tia- 942 site certification</li> </ul> <p>Documents to be submitted:- submit suitable, verifiable evidence to demonstrate the above. The data centers should have become operational (i.e. commissioned with live servers on or after 01.01.2010 and on or before 31.03.2016</p>	Tier III Data Center OR Tier IV standards, rest as per “EOI” document.
9	“Annexure-A” Eligibility criteria, Page no. 11	Each of the Data Centers at 4 above should have had: Server room (S) floor area at least 10,000 sq. ft. ( 4645.152 sp. M)	Yes required
10	“Annexure-A” Eligibility criteria, Page no. 11 & 12	<p>Should have constructed the following number of commercial buildings in India or abroad, on or after 01.01.2005 and or before 31.03.2016, with LEED Certification granted by the Green building certification institute (GBCI):</p> <p>Certification Minimum level (any No. of One) Buildings</p>	Leed certification is not mandatory but, the project building will be duly certified by Leed certification (through third party) as per High Court requirement.

		Gold Platinum	
11	-	As mutually agreed upon, we can also submit the Tier III certificate instead of Tier IV as mentioned earlier in your tender notice. We will be submitting our Tier III certificate during EOI submission	Yes, Tier III certification shall be accepted.
12	-	As discussed, the Leed certificate (from the bidder) is not mandatory, since the same is issued by a third party. But, the project building will be duly certified by Leed certification (through third party) as per your requirement.	Yes Leed certification is not mandatory but, the project building will be duly certified by Leed certification (through third party) as per High Court requirement.
13	-	The abide by the legal requirements and preparing proper legal documents, we had requested you to extend the EOI submission date for 15 days from the actual date of submission as mentioned in the tender notice.	<u>Yes, the date for submission of EOI is extended till 21<sup>st</sup> December, 2016 before 3:00 PM and EOI shall be opened on same day at 3:30 PM.</u>

**Note:-**

1. The Registrar General, High Court of Madhya Pradesh has full rights to accept or reject any "EOI", without assigning any reason.
2. The Registrar General, High Court of Madhya Pradesh has right to alter the scope of work as per the requirement.
3. All Prospective bidders / vendors are requested to submit the "EOI" with all relevant documents .
4. The above clarifications are for all the prospective bidders' for their reference and necessary action.
5. **The submission date of this "EOI" is hereby extended up to 21<sup>st</sup> December, 2016 till 3:00 P.M. and "EOI" shall be opened on same day at 3:30 PM**
6. All future correspondence / clarifications / addendum/ corrigendum shall be available in the website of the High Court of Madhya Pradesh i.e. [www.mphc.gov.in](http://www.mphc.gov.in) and Government tender portal [www.tenders.gov.in](http://www.tenders.gov.in) .

**Sd/-**

**REGISTRAR GENERAL**