

**HIGH COURT OF MADHYA PRADESH: JABALPUR**

**// CORRIGENDUM //**

**No. Reg (IT) (SA)/ 2018/832**

**Jabalpur, Dated:01-06-2018**

**Sub:-** Corrigendum for date extension and change in technical specification regarding the tender for supply, installation, commissioning and maintenance of Air-Conditioners for the Server Rooms of the Subordinate Courts in the State of Madhya Pradesh.

**Ref:-** Tender No. Reg (IT) (SA)/2018/714, dated: 02.05.2018.

The last date for submission of tender regarding the ***“supply, installation, commissioning and maintenance of Air-Conditioners”*** for **Subordinate Courts in the State of Madhya Pradesh** is hereby extended till **25<sup>th</sup> June, 2018 latest by 03:00 PM**. The tender shall be opened on same day at **03:30 PM**. The detail of the tender document is available in the official website of the High Court [www.mphc.gov.in](http://www.mphc.gov.in) and Madhya Pradesh e-Procurement portal [www.mpeproc.gov.in](http://www.mpeproc.gov.in) . If the date of tender submission is declared as holiday then the tender shall be submitted / opened on next working day.

**Sd/-**

**PRINCIPAL REGISTRAR (J)**

**Encl: As Above**

## Section – VII

### 7. TECHNICAL SPECIFICATIONS:-

All the products/equipment/items supplied should be quoted with:

- (i) Five years comprehensive Onsite Warranty and support on all supplied items/ products.
- (ii) All the necessary and required cables and other accessories.
- (iii) Enclose all product catalogues and technical **brochures of the products / items along with MANUFACTURER AUTHORIZATION FORM (MAF) addressed to the "Registrar General, High Court of Madhya Pradesh", Jabalpur (M.P.)**
- (iv) **The Original equipment manufacturer can authorize more than one partner for participation in the bid.**

S.No.	Parameter	Minimum specification required	Technical compliance Yes / No
1	Product certification	ISO 9001 and 14001 certified	
2	Type	Wall Mount split type	
3	Nominal Cooling Capacity [Ton/(Kcal/hr)]	2.0/6000 Ton/(Kcal/hr)	
4	Filters	Active dust, Active carbon, Nano Silver etc. or equivalent or better.	
5	Tube	<b>Copper tube</b> is required in the AC.	
6	Indoor unit	LED display, Self diagnosis, Auto restart etc.	
7	Remote	Sleep mode, Turbo, swing, LCD display, lock, timer etc.	
8	Coil Material	CU (Copper)/ Aluminum	
9	Air vent	Auto	
10	Moisture removal	Yes Required	
11	New BEE Star ratings	5 Star rating under <b>new guidelines of year 2018</b>	
12	Minimum 5 Meters of Copper Pipe for Installation and Commissioning.	Yes Required	
13	Eco Friendly Refrigerant	Yes Required	

**Note:-1. Please submit the product catalogue / brochure.**

2. **The bidder has to give the details , if there is any deviation in the Data sheet. The bidder may quote better / higher specifications.**