## HIGH COURT OF MADHYA PRADESH: JABALPUR

## // CLARIFICATION //

#### No. Reg(IT)(SA)/2017/1135

#### Jabalpur, Dated:06-10-2017

- Subject:-The matter relates to publish the clarification/ reply of the Pre-Bid meeting dated: 03<sup>rd</sup> October, 2017 of the tender regarding the "Supply, Installation, Commissioning, Maintenance of DG sets" in the Subordinate Courts in the State of Madhya Pradesh with to tender reference the no. Reg(IT)(SA)/2017/1094, Dated:18.09.2017.
- Ref: Pre-Bid Meeting Dated: 03<sup>rd</sup> October, 2017 at 11:30 AM.

### Reply / clarification to the pre-bid queries

| S.No. | Specification  | Technical compliance |
|-------|--|----------------------|
|       | •  | Yes / No             |
| 1.    | Supplying, Installation, testing and commissioning of 5 KVA of 1500 RPM silent model Air cooled / water cooled ready to use Diesel Generating Set of Kirloskar / Mahindra / Jakson Cummins / Greaves cotton or equivalent reputed brand. The engine shall of standard design of the original make Engine complete with kirloskar Green / Crompton Greaves / stamp ford /Cotton Greaves or equivalent brand of repute make single phase 240 V AC Brushless type Alternator confirming to IS 13364 (Part-1) 1992 (reaffirmed 2003) complete with Accoustic Enclosure conforming to <u>CPCB</u> norms, with AMF panel and 1 x 12V Excide Battery (wet cell) complete with charging of 1 No. to each set, PCC foundation to each DG Set, Copper plate earthing Set-2 numbers to each DG Set, supply, fixing of 1 x 10 mm 2 / 2x55 mm2 PVC aluminum armored cable 20 meter for each DG Set. |                      |
| 2.    | The engine shall be of standard design of<br>the original manufactures. It should be 4<br>stroke cycles, water cooled/ Air Cooled,<br>naturally aspirated / turbo charged (as per<br>manufacturer standard), diesel engine   |                      |

"Revised Specification –A"

|     | developing suitable BHP for giving a           |  |
|-----|--|--|
|     | power rating as per ISO 8528 standards         |  |
|     | in KVA at the load terminals of alternator     |  |
|     | at 1500 rpm at actual site conditions          |  |
| 3.  | District wise service centers along with       |  |
|     | the name of the resident engineer, its         |  |
|     | local address and their contact details.       |  |
| 4.  | Authorization letter from OEM to whom it       |  |
|     | may concern for.                               |  |
|     | a. Make and HP of Engine.                      |  |
|     | b. Make of Alternator.                         |  |
|     |  |  |
|     | c. Make of Accoustic canopy.                   |  |
| 5.  | The name of the top five customers in          |  |
|     | connections with previous supply order         |  |
|     | (attach supply order) of 5/10 KVA DG sets      |  |
|     | each along with compliance report with         |  |
|     | their address and telephone number.            |  |
| 6.  | Any National or International Certificate /    |  |
|     | Award receive for good quality and             |  |
|     | performance.                                   |  |
| 7.  | All the civil work and electrical work that is |  |
|     | required for installation of DG sets is to be  |  |
|     | borne by the respective vendor.                |  |
| 8.  | BIS and CPCB – II certification                |  |
| 9.  | Prime Power rating having 10% overload         |  |
| 0.  | capacity.                                      |  |
| 10. | Overload capacity for one hour for every       |  |
| 10. |  |  |
|     | 11 hours continuous running at full load       |  |
| 4.4 | (10%)  |  |
| 11. | Automatic mains failure (AMF) control          |  |
|     | panel, where applicable, shall be able to      |  |
|     | start up the dg set and transfer the load      |  |
|     | on to the dg set on mains failure without      |  |
|     | requiring any human intervention.              |  |
|     | similarly on restoration of mains supply, it   |  |
|     | shall be able to transfer the load to mains    |  |
|     | supply and switch off the DG set               |  |
|     | automatically.                                 |  |
| 12. | Control panel should have protection           |  |
|     | against under voltage, over voltage, under     |  |
|     | frequency, over frequency, low battery         |  |
|     | voltage, over current, earth fault, short      |  |
|     | circuit, phase sequence change etc.            |  |
| 13. | Equipped with suitable voltmeter,              |  |
| 10. | ammeter, frequency meter, power factor         |  |
|     |  |  |
|     | meter, battery charger where battery is        |  |
|     | used, indicators, various switches and         |  |
|     | cutout /MCB/ MCCB/ contactor/circuit           |  |
|     | breaker of all appropriate rating and          |  |
|     | accuracy class as per trade practice for       |  |
|     | better utility.                                |  |
| 14. | Pretreated and powder coated accoustic         |  |
|     | enclosure of CRCA sheet                        |  |
|     |  |  |

| 15. | Accoustic enclosure of CRCA sheet             |  |
|-----|---|--|
|     | thickness (minimum thickness 1.6 mm)          |  |
| 16. | Thickness of foam (minimum 40 mm)             |  |
| 17. | Standard set of tools consisting of a set of  |  |
|     | 3 spanners, one screw driver, one             |  |
|     | standard plier and one nose plier of          |  |
|     | appropriate size shall be provided to the     |  |
|     | consignees along with DG sets,                |  |
| 18. | Availability of type test report from central |  |
|     | government/ NABL /ILAC accredited             |  |
|     | laboratory to prove conformity to the         |  |
|     | specification for each rating for engine.     |  |
| 19. | Name and address of laboratory                |  |
| 20. | DG sets shall meet the requirements of        |  |
|     | environmental (protection) rules 1986 as      |  |
|     | laid down by min. of environment &            |  |
|     | forests read with GSR 371 (E) dated           |  |
|     | 17.5.2002, GSR 520 (E) dated 1.7.2003,        |  |
|     | no. 448 (E) dated 12.07.2004 , GSR            |  |
|     | 771(E) dated 11.12.2013 GSR 232 (E)           |  |
|     | dated 31.03.2014, gazette notification        |  |
|     | no.167 dated. 31.03.2014 and gazette          |  |
|     | notification no. 578 dated. 11.11.2014. in    |  |
|     | respect of noise and emission norms. the      |  |
|     | latest amendments to above GSRS shall         |  |
|     | be applicable as and when amended by          |  |
|     | ministry of environment and forest.           |  |
| 21. | Foundation shall be of PCC type with the      |  |
|     | ratio of 4:2:1. The length and breadth of     |  |
|     | the foundation shall be 300 mm more           |  |
|     | from the respective length and breadth of     |  |
|     | the DG set. The height of the foundation      |  |
|     | shall be 400 mm i.e. 200 mm below and         |  |
|     | 200 mm above the ground level. The            |  |
|     | foundation work shall be done by the firm.    |  |
| 22. | ISI marking.                                  |  |

## Note:-

- Only those firms shall be considered for the bid who is having 05 years of experience in DG Sets.
- **2.** All the pages of the bids and Annexure seal and signed by the authorized officers of the company / vendor.
- **3.** The bidder has to quote only 01 product of single make / brand at a time and not multiple brands for same item.
- **4.** The Original equipment manufacturer can authorize more than one partner for participation in the bid.
- 5. Back-to-Back support letter is to be submitted by OEM regarding support of the quoted products.

- 6. The Registrar General, High Court of Madhya Pradesh has full rights to accept or reject any bid, without assigning any reason.
- 7. The Registrar General, High Court of Madhya Pradesh has right to alter the scope of work as per the requirement.
- 8. All Prospective bidders are requested to submit the bid with all relevant documents and product brochures / catalogues
- **9.** The above clarifications / addendum are for all the prospective bidders' for their tender reference and necessary action.
- **10.** On introduction of new levy / taxes / duties the rate / price of items shall be change in same proportionate.
- **11.** The rest of the tender conditions shall remain same.

# *Sd/-*REGISTRAR GENERAL